



中国国家强制性产品认证证书

证书编号: 2016010304840913

委托人名称、地址

Carlo Gavazzi Ltd.
BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

生产者(制造商)名称、地址

Carlo Gavazzi Ltd.
BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

生产企业名称、地址

Carlo Gavazzi Ltd.
BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

产品名称和系列、规格、型号

电机软起动器

RSBT; Ui:630V;Ue:AC220, AC400V;Ith=Ie:16A(RSBT..16..V...), Ith=Ie:25A
(RSBT..25..V...), Ith=Ie:32A(RSBT..32..V...), IP20;AC-53b;3P;型号解释见附件

产品标准和技术要求

GB 14048.6-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2016年01月27日

有效期至: 2021年01月27日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1287797



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2016010304840913

NAME AND ADDRESS OF THE APPLICANT

Carlo Gavazzi Ltd.
BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

NAME AND ADDRESS OF THE MANUFACTURER

Carlo Gavazzi Ltd.
BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

NAME AND ADDRESS OF THE FACTORY

Carlo Gavazzi Ltd.
BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

NAME, MODEL AND SPECIFICATION

Motor Softstarter

RSBT; Ui:630V;Ue:AC220, AC400V;Ith=Ie:16A(RSBT..16..V...), Ith=Ie:25A
(RSBT..25..V...), Ith=Ie:32A(RSBT..32..V...), IP20;AC-53b;3P;See the
Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.6-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Jan.27, 2016 Date of expiry: Jan.27, 2021

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:


Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1287797



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2016010304840913

纸号: 1287797

型号的解释:

NOMENCLATURE BREAKDOWN AND RATINGS FOR RSBT 45MM Series:

<u>RSB</u>	<u>T</u>	<u>40</u>	<u>16</u>	<u>E</u>	<u>V5</u>	<u>I</u>	<u>HP</u>	<u>V</u>	<u>XXXX</u>
I	II	III	IV	V	VI	VII	VIII	IX	X

I - Designated basic series:

RSB - Compressor Softstarter

II - Construction Type:

T - 3 Phase Compressor

III - Rated Operational Voltage:

22 - 220 Vac (+/-15%)

40 - 400 Vac (+/-15%)

IV - Nominal IEC current rating (UL FLA current at 220 Vac):

16 - max. 16 A

25 - max. 25 A

32 - max. 32 A

V - Control Voltage:

E - 110-400 Vac (+/-15%)

VI - Options:

V1 - Without RFPM Auxiliary Relay Module

V2 - With RFPM Auxiliary Relay Module

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2016010304840913

纸号: 1287797

VC – With Modbus Module
V5 – UL approved, Without RFPM Auxiliary Relay Module
V6 – UL approved, With RFPM Auxiliary Relay Module

VII Options:

0 – Without Din-Rail Adaptor
1 – With Din-Rail Adaptor

VIII Options:

HP – With HP algorithm
Blank – Without HP algorithm

IX - VDE Approval (optional):

V – VDE approved
Blank – Not VDE approved

X - Function (optional):

xxxx – Special function
Blank – Standard function

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

