



# 中国国家强制性产品认证证书

证书编号：2017010304987845

### 委托人名称、地址

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

### 生产者（制造商）名称、地址

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

### 生产企业名称、地址

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

### 产品名称和系列、规格、型号

电机软起动器

RSGD 40, RSGD 60(型号解释详见附件); Ui:

690V; Ith:12A, 16A, 25A, 32A, 37A, 45A; Ie:12A, 16A, 25A, 32A, 37A, 45A; RSGD 40:Ue:

AC220-400V; Pe:5.5kW, 7.5kW, 11kW, 15kW, 18.5kW, 22kW; RSGD 60:Ue:

AC220-600V; Pe:9kW, 11kW, 20kW, 22kW, 30kW, 37kW; 使用类别: AC-53b; 极数: 3P; 外壳防护等级: IP20

### 产品标准和技术要求

GB/T 14048.6-2016

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，特发此证。

发证日期：2017年07月25日 有效期至：2022年07月25日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任：



## 中国质量认证中心



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

**CERTIFICATE NO.: 2017010304987845**

## NAME AND ADDRESS OF THE APPLICANT

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

## NAME AND ADDRESS OF THE MANUFACTURER

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

## NAME AND ADDRESS OF THE FACTORY

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

## PRODUCT NAME, MODEL AND SPECIFICATION

Motor Softstarter

RSGD 40, RSGD 60; Ui: 690V;Ith:12A,16A,25A,32A,37A,45A;Ie:12A,16A,25A,32A,37A,45A; RSGD 40:Ue: A C220-400V;Pe:5.5kW,7.5kW,11kW,15kW,18.5kW,22kW; RSGD 60:Ue: AC220-600V;Pe:9kW,11kW,20kW,22kW, 30kW,37kW; Utilization Category: AC-53b;Poles: 3P;IP20

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

**Valid from:** Jul.25,2017

**Valid until:** Jul.25,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



## CHINA QUALITY CERTIFICATION CENTRE



# 中国国家强制性产品认证证书

附录

第 1 页 共 2 页

证书编号: 2017010304987845

纸号: 1759429

型号解释:

RSG	D	60	45	G	G	VP	2	1	XXXX
I	II	III	IV	V	VI	VII	VIII	IX	X

I - Designated basic series: 命名基本系列

RSG - Generic Softstarter

II - Construction Type: 结构类别

D - 2 (Dual) Phase Control

III - Rated Operational Voltage: 额定操作电压

40 - 220÷400 V ac (+10% / -15%)

60 - 220÷600 V ac (+10% / -15%)

IV - Nominal IEC current rating (UL FLA current at 400 V ac): IEC 列名的额定电流

12 - max. 12 A (12.0 A)

16 - max. 16 A (17.0 A)

25 - max. 25 A (25.0 A)

32 - max. 32 A (32.0 A)

37 - max. 37 A (37.0 A)

45 - max. 45 A (45.0 A)

V - Control Voltage: 控制电压

E - 110÷400 V ac (+10% / -15%)

F - 24 V ac/V dc (+10% / -10%)

G - 100÷240 V ac (+10% / -15%)

VI - External Supply Voltage: 外部供应电压

0 - Not required (for Control Voltage "E" and "F" digit) 不要求

F - 24 V ac/V dc (+10% / -10%) (for Control Voltage "F" digit only)

注: 此附录与证书同时使用时有效。



主任:



## 中国质量认证中心



# 中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2017010304987845

纸 号: 1759429

G - 100÷240 Vac (+10% / -15%) (for Control Voltage "G" digit only)对 G 控制电压适用

VII - Options:可选项

VP - Panel Mounting 面板装饰

VD - DIN Mounting DIN 装饰

VX - DIN/Panel Mounting with Heatsink (for "25", "32", "37", "45" Current digit)

VIII - Options:可选项

0 - No Changeover relay outputs 不带继电器输出反转器

2 - 2 x Changeover relay outputs 带2个继电器输出反转器

IX - Options:

0 - No Overload Function

1 - With Overload Function

X - Options:

0 - No Fan

1 - With Fan

XI - Communication (optional):

C - Communication

Blank - No Communication

XII - Function (optional):功能可选项

xxxx - Special function 特殊功能(固件版本)

Blank - Standard function 标准功能

注: 此附录与证书同时使用时有效。



主 任:



## 中国质量认证中心