



中国国家强制性产品认证证书

证书编号: 2016010304871083

委托人名称、地址

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

生产者(制造商)名称、地址

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

生产企业名称、地址

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

产品名称和系列、规格、型号

电机软起动器

RSWT; Ui: 630V(RSWT40), 690V (RSWT60); Uimp:4kV;Ue: AC220-400V,AC220-600V;lth=le: 12A (RSWT..12.V...);lth=le: 16A (RSWT..16.V...);lth=le: 25A (RSWT..25.V...);外壳防护等级: IP20; 使用类别: AC-53b; 极数: 3P.型号解释见附件

产品标准和技术要求

GB/T 14048.6-2016

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2017年10月16日 有效期至: 2021年05月27日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016年05月27日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2016010304871083

NAME AND ADDRESS OF THE APPLICANT

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

NAME AND ADDRESS OF THE MANUFACTURER

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

NAME AND ADDRESS OF THE FACTORY

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

PRODUCT NAME, MODEL AND SPECIFICATION

Motor Softstarter

RSWT; Ui: 630V(RSWT40), 690V (RSWT60); Uimp:4kV;Ue: AC220-400V,AC220-600V;Ith= Ie: 12A (RSWT..12.V....);Ith= Ie: 16A (RSWT..16.V....);Ith= Ie: 25A (RSWT..25.V....);Levels of Protection: IP20;Utilization Category: AC-53b; Poles: 3P.See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Oct.16,2017

Valid until: May.27,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: May.27,2016

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

<http://www.cqc.com.cn>

Section 9, No. 188, Nanshuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666

Q 1817843



中国国家强制性产品认证证书

附录：

第 1 页 共 2 页

证书编号：2016010304871083

纸号：1817843

型号的解释：

NOMENCLATURE BREAKDOWN AND RATINGS FOR RSWT 45MM Series:

RSW	T	40	16	E	0	V10	1	XXXX
I	II	III	IV	V	VI	VII	VIII	IX

I - Designated basic series:

RSW - Pump Softstarter

II - Construction Type:

T - 3 Phase Compressor

III - Rated Operational Voltage:

40 - 220-400 Vac (+10% / -15%)

60 - 220-600 Vac (+10% / -15%)

IV - Nominal IEC current rating (UL FLA current at 220 Vac):

12 - max. 12 A

16 - max. 16 A

25 - max. 25 A

V - Control Voltage:

E - 110+400 V/ac (+10% / -15%)

注：此附录与证书同时使用时有效。



主任：



中国质量认证中心



中国国家强制性产品认证证书

附录：

第 2 页 共 2 页

证书编号：2016010304871083

纸号：1817843

F - 24 V ac/V dc (+10% / -10%)
G - 100+240 V ac (+10% / -15%)

VI External Supply Voltage:

0 - Not required (for Control Voltage "E" and "F" digit)
F - 24 V ac/V dc (+10% / -10%) (for Control Voltage "F" digit only)
G - 100+240 V ac (+10% / -15%) (for Control Voltage "G" digit only)

VII - Options:

V00 - No Overload Protection
V10 - With Overload Protection

VIII Options (optional):

1 - With Fan
Blank - No Fan

IX Function (optional):

xxxx - Special function
Blank - Standard function

注：此附录与证书同时使用时有效。



主任：



中国质量认证中心