



中国国家强制性产品认证证书

证书编号: 2016010304840913

委托人名称、地址

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

生产者(制造商)名称、地址

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

生产企业名称、地址

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

产品名称和系列、规格、型号

电机软起动器

RSBT; Ui: 630V; Uimp:4kV;Ue: AC220V,AC400V;lth= le: 16A (RSBT..16.V....);lth= le: 25A (RSBT..25.V....);lth= le: 32A (RSBT..32.V....);外壳防护等级: IP20; 使用类别: AC-53b; 极数: 3P.型号解释见附件

产品标准和技术要求

GB/T 14048.6-2016

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2017年10月16日 有效期至: 2021年01月27日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016年01月27日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2016010304840913

NAME AND ADDRESS OF THE APPLICANT

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

NAME AND ADDRESS OF THE MANUFACTURER

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

NAME AND ADDRESS OF THE FACTORY

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

PRODUCT NAME, MODEL AND SPECIFICATION

Motor Softstarter

RSBT: Ui: 630V; Uimp:4kV;Ue: AC220V,AC400V;Ith= Ie: 16A (RSBT..16.V....);Ith= Ie: 25A (RSBT..25.V....);Ith= Ie: 32A (RSBT..32.V....);Levels of Protection: IP20; Utilization Category: AC-53b; Poles: 3P. See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Oct.16,2017

Valid until: Jan.27,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jan.27,2016

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录：

第 1 页 共 3 页

证书编号：2016010304840913

纸号：1817842

型号的解释：

NOMENCLATURE BREAKDOWN AND RATINGS FOR RSBT 45MM Series:

<u>RSB</u> I	<u>T</u> II	<u>40</u> III	<u>16</u> IV	<u>E</u> V	<u>V5</u> VI	<u>1</u> VII	<u>HP</u> VIII	<u>V</u> IX	<u>XXXX</u> X
-----------------	----------------	------------------	-----------------	---------------	-----------------	-----------------	-------------------	----------------	------------------

I - Designated basic series:

RSB - Compressor Softstarter

II - Construction Type:

T - 3 Phase Compressor

III - Rated Operational Voltage:

22 - 220 Vac (+/-15%)

40 - 400 Vac (+/-15%)

IV - Nominal IEC current rating (UL FLA current at 220 Vac):

16 - max. 16 A

25 - max. 25 A

32 - max. 32 A

V - Control Voltage:

E - 110-400 Vac (+/-15%)

注：此附录与证书同时使用时有效。



主任：



中国质量认证中心



中国国家强制性产品认证证书

附录：

第 2 页 共 3 页

证书编号：2016010304840913

纸号：1817842

VI - Options:

- V1 - Without RFPM Auxiliary Relay Module
- V2 - With RFPM Auxiliary Relay Module

- VC - With Modbus Module
- V5 - UL approved, Without RFPM Auxiliary Relay Module
- V6 - UL approved, With RFPM Auxiliary Relay Module

VII Options:

- 0 - Without Din-Rail Adaptor
- 1 - With Din-Rail Adaptor

VIII Options:

- HP - With HP algorithm
- Blank - Without HP algorithm

IX - VDE Approval (optional):

- V - VDE approved
- Blank - Not VDE approved

X - Function (optional):

- xxxx - Special function

注：此附录与证书同时使用时有效。



主任：



中国质量认证中心



中国国家强制性产品认证证书

附录：

第 3 页 共 3 页

证书编号：2016010304840913

纸号：1817842

Blank - Standard function

注：此附录与证书同时使用时有效。



主任：



中国质量认证中心