



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2014010304702907

## NAME AND ADDRESS OF THE APPLICANT

CARLO GAVAZZI AUTOMATION (KUNSHAN) CO., LTD  
The South of Kunjia Road, Kunshan Development Zone, Jiangsu Province

## NAME AND ADDRESS OF THE MANUFACTURER

CARLO GAVAZZI AUTOMATION (KUNSHAN) CO., LTD  
The South of Kunjia Road, Kunshan Development Zone, Jiangsu Province

## NAME AND ADDRESS OF THE FACTORY

CARLO GAVAZZI AUTOMATION (KUNSHAN) CO., LTD  
No.347, Kunjia Road, Kunshan Development Zone Jiangsu Province

## PRODUCT NAME, MODEL AND SPECIFICATION

Solid State Contactor

RM, RAM; Ui: 690V; Uimp: 4kV; RM: Ue: AC230V/400V/480V/600V; Ith= Ie: 5A, 15A, 20A, 30A; RAM: Ue: AC230V/600V; Ie: 5A, 15A, 17A, 20A, 30A; Ue: AC690V; Ie: 17A, 20A, 30A; Ith: 5A, 15A, 17A, 20A, 30A; Utilization Category: AC-53a; IP20; Poles: 1P; See the Appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO.CNCA-C03-02:2014).

Valid from: Apr.02,2019

Valid until: Apr.02,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jun.25,2014

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE



# 中国国家强制性产品认证证书

附录:

第 1 页 共 4 页

证书编号: 2014010304702907

纸号: 1753331

型号的解释:

RM1 系列

R	M	1	□	□	□	□	XXXXX
I	II	III	IV	V	VI	VII	X

I - Designated Basic Series: 指定的基本系列

R - Solid State Contactor: 固态接触器

II - Construction Type: 结构形式

M - Modular Build 模块化构造

III - Number of phase: 相数

1 - Single phase 单相

IV - Switching type: 触发类型

A - Zero Cross Switching 过零触发

B - Instant On Switching 随机触发

V - Voltage Rating: 额定电压

23 - 230 V.

40 - 400 V.

48 - 480 V.

60 - 600 V

注: 此附录与证书同时使用时有效。



主任:



## 中国质量认证中心



# 中国国家强制性产品认证证书

附录:

第 2 页 共 4 页

证书编号: 2014010304702907

纸号: 1753331

VI - Control Voltage: 控制电压

D - 3 to 32 V dc

A - 20 to 280 V ac or 22 to 48 V dc

M - 4.25 to 27 V ac or 4.25 to 36 V dc

A1 - 110Vac

A2 - 230Vac

A4 - 400Vac

VII - Current specification: 电流说明

25 - 5 A

50 - 15 A

75 - 20 A

100 - 30 A

X - Suffix for Specials: 特殊的后缀

Blank - Standard Function 空白 - 标准功能

XXXX - Special Function - 特殊功能

注: 此附录与证书同时使用时有效。



主任:



## 中国质量认证中心



# 中国国家强制性产品认证证书

附录:

第 3 页 共 4 页

证书编号: 2014010304702907

纸号: 1753331

RAM1 系列

R	AM	1	□	□	□	□	XXXXX
I	II	III	IV	V	VI	VII	X

I - Designated Basic Series: 指定的基本系列

R - Solid State Contactor: 固态接触器

II - Construction Type: 结构形式

AM - Modular Build 模块化构造

III - Number of phase: 相数

1 - Single phase 单相

IV - Switching type: 触发类型

A - Zero Cross Switching 过零触发

B - Instant On Switching 随机触发

V - Voltage Rating: 电压等级

23 - 230 V

60 - 600 V

注: 此附录与证书同时使用时有效。



主任:



## 中国质量认证中心



# 中国国家强制性产品认证证书

附录:

第 4 页 共 4 页

证书编号: 2014010304702907

纸号: 1753331

69 - 690 V

- VI - Control Voltage: 控制电压  
D - 3 to 32 Vdc (for 230Vac and 400Vac version)  
D - 4 to 32 Vdc (for 480/690Vac version)  
A - 20 to 280 V ac or 22 - 48 V dc

- VII - Current specification: 电流说明  
25 - 5 A  
50 - 15 A  
75 - 17 A  
100 - 20 A  
125 - 30 A

- X - Suffix for Specials 特殊的后缀  
Blank - Standard Function 空白 - 标准功能  
XXXX - Special Function--特殊功能

注: 此附录与证书同时使用时有效。



主任:



## 中国质量认证中心