



中国国家强制性产品认证证书

证书编号: 2017010303032286

委托人名称、地址

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

生产者(制造商)名称、地址

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

生产企业名称、地址

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

产品名称和系列、规格、型号

固态继电器

RGC2P...15..., RGC2P...25..., RGC2P...40..., RGC2P...75..., RGC3P...20..., RGC3P...30..., RGC3P...65...;
Uimp:6kV; Ui:630V; Ue:AC207-600V; Ith:RGC2P...:15A,27A,40A,75A;RGC3P...:20A,30A,66A;
Ie:RGC2P:15A,25A,40A,75A; RGC3P...:20A,30A,65A; 使用类别: AC-12; 外壳防护等级:IP20. 型号解释
详见附件

产品标准和技术要求

GB/T14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2019年05月08日 有效期至: 2022年12月18日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2017年12月18日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心

<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

Q 2303412



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2017010303032286

NAME AND ADDRESS OF THE APPLICANT

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

NAME AND ADDRESS OF THE MANUFACTURER

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

NAME AND ADDRESS OF THE FACTORY

Carlo Gavazzi Ltd.

BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

PRODUCT NAME, MODEL AND SPECIFICATION

Solid State Relay

RGC2P...15..., RGC2P...25..., RGC2P...40..., RGC2P...75..., RGC3P...20..., RGC3P...30..., RGC3P...65...; Ui mp:6kV; Ui:630V; Ue:AC207-600V; lth:RGC2P...:15A,27A,40A,75A;RGC3P...:20A,30A,66A; le:RGC2P:15A, 25A,40A,75A; RGC3P...:20A,30A,65A; Utilization Category : AC-12; Levels of Protection :IP20. See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.08,2019

Valid until: Dec.18,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Dec.18,2017

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666

Q 2303412



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2017010303032286

纸 号: 2303412

型号的解释:

NOMENCLATURE BREAKDOWN AND RATINGS FOR RGC 3Phase Series:

RGC	3	P	60	I	65	C1	A	F	M	xxxx
I	II	III	IV	V	VI	VII	VIII	IX	X	XI

- I - Designated basic series:
RGC - Solid State Relay with Heat-sink
- II - Construction Type:
2 - 2Phase Switching 3 - 3Phase Switching
- III - Switching Mode:
P - Proportional Control
- IV - Rated Operational Voltage:
60 - 207-600 Vac (+10%/-15%)
- V - Control Voltage:
AA - 4-20mA DC
I - 0-20mA DC, 4-20mA DC, 12-20mA DC
V - 0-5 VDC, 1-5VDC, 0-10VDC or 10VDC(digital)
- VI - Rated Operational Current:
15 - 15 AAC 40 - 40 AAC
20 - 20 AAC 65 - 65 AAC
25 - 25 AAC 75 - 75AAC
30 - 30 AAC
- VII - Switching Mode:
E - Phase Angle, S - Soft Start + 1 Full Cycle, S16 - Soft Start + 16 Full Cycles
C1 - 1 Full Cycle, C4 - 4 Full Cycles, C16 - 16 Full Cycles
- VIII - External Supply (Us):
D - 24 VDC/AC (+20%/-15%) or 24VAC (+15%/-15%)
A - 90 - 250 VAC
- IX - Features (optional):
F - Integrated Fan
M - Monitoring for Mains Loss, Load Loss, S/C, O/C, OTP, EMR and AUX output
- X - Features (optional):
P - Integrated OTP, Mains Loss and EMR output
F - Integrated Fan
M - Monitoring for Mains Loss, Load Loss, S/C, O/C, OTP, EMR and AUX output
- XI - Special Feature:
XXXX - Special Feature
Blank - Standard Feature

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

变更结论 Modification Approval

证书编号 Certificate No. : 2017010303032286

申请编号 Application No. : A2019CCC0303-3113674

申请人(委托人) Applicant: Carlo Gavazzi Ltd. / Carlo Gavazzi Ltd.

证书编号 Certificate No.(变更前 Original): 2017010303032286

变更产品名称: 固态继电器

Name of Product Modified: Solid State Relay

变更情况 Situation of Modification (见下表 See table below) :

序号	项目 Item	变更前 Original	变更后 Present
1	标准变更	GB/T14048.5-2008;	GB/T14048.5-2017;
2	底座(壳体)供应商变更	1) Lati Industria Termoplastic; 2) Radici Group	1)Lati Industria Termoplastic; 2)LANXESS; 3)BASF; 4)Vamp Technologies S.p.A.

现批准以上变更。

Above Modification is approved. The present will replace the original.

批准日期 (Date) : 2019年05月08日

第 1 页 / 共 1 页



主任:

陆杨



中国质量认证中心